

# 16<sup>th</sup> TECHNICAL COMMITTEE MEETING

16<sup>th</sup> Technical Committee meeting for granting Technical Sanction to the projects for which Administrative Sanction has been granted and for the scrutiny and appraisal of the project reports prepared by the PMU.

Meeting No. 16

Date – 1<sup>st</sup> March 2021, 11.00am

Venue: Online (Google meet)

## AGENDA

1. Discussion of estimate given for according Technical Sanction to the 22 projects for which Administrative Sanction has been granted
2. Scrutiny and Appraisal of Soil investigation (5 Nos) prepared by PMU.

## PRESENT

S. No	Name	Designation and Office Address	Signature
1	Sri Johnson	Chief Engineer, LSGD	
2	Dr. Nivin Philip	Professor, Saint Gits College of Engineering	
8	Sri Vishnukumar G	Project Director, PMU RKI LSGD	
9	Sri Sajish R	Executive Engineer, PIU RKI LSGD	
10	Sri Shiju Chandran	Assistant Executive Engineer, PMU RKI LSGD	
11	Shainy N	Assistant Executive Engineer, PMU RKI LSGD	
12	Sathyanath B	Assistant Executive Engineer, PMU RKI LSGD	
13	Jiju V	Assistant Engineer, PMU RKI LSGD	
14	Binod S	Assistant Engineer, PMU RKI LSGD	
15	Jithu Raj	Assistant Engineer, PMU RKI LSGD	
16	Binil Gopinath	Assistant Engineer, PMU RKI LSGD	
17	Sharavaneswar	Assistant Executive Engineer, PMU RKI LSGD	
18	Rasheed	Assistant Engineer, PMU RKI LSGD	

Sl.No.	Description	Action
--------	-------------	--------

1.1	The Chief Engineer, LSGD informed that the proposed meeting is scheduled for discussing the 22 DPRs submitted by PD, PMU for Technical sanction which Administrative Sanction has been accorded by the Government based on the designs approved by the Technical Committee and also for Scrutiny and approval of soil investigation estimate (5 nos) prepared by PMU & Consultants.	-
<b>DISCUSSIONS</b>		
2.1	The Chief Engineer informed that only 6 DPRs and 5 Soil Investigation estimate can be accorded technical sanction based on the design and estimate approved by the Technical Committee has been scrutinized in the Office of Chief Engineer, LSGD. Balance 16 estimate are sent back to PMU through PRICE Software for making necessary corrections as mentioned.	
2.2	PD, PMU and the Engineers of PMU RKI LSGD explained the clarification of the queries mentioned in estimate and also the details of DR masonry work mentioned in CTE circular	
2.3	Technical committee decided to give separate DR footing for DR masonry works especially in water logged areas and that to be mentioned in DPRs and other areas to be followed as per CTE circular.	PD, PMU
2.4	Chief Engineer opined that for Drain works -Side wall, 20cm thickness to be given on road side and 15cm thickness on other side. If depth of the drain is less than 60 cm 15cm thickness can be given for both sides.	PD, PMU
2.5	The Chief Engineer suggested that minimum 1mx1m size should be given for cross drain. If the velocity of flow is less deposit of sand and materials will occur that will block the drain so minimum of 1mx1m to be given.	PD, PMU
2.5	The Chief Engineer opined that estimate should be prepared either in MORD or MORTH specification. Combined specification is not allowed for estimate preparation.	PD, PMU
2.6	The Chief Engineer opined that technical sanction can be accorded for 11 Works after election MCC.	
<b>DECISIONS</b>		
3.1	Technical sanction for 11 works that scrutinised in Office of Chief Engineer can be accorded after the election MCC.	
<b>NEXT MEETING</b>		

Next Technical Committee meeting will be informed well in advance

Chief Engineer

1. *D. Nivina Philip*

2. *Dr. Vekkar R* VLS

**JOHNSON. M.**  
**PEN 538757**  
**CHIEF ENGINEER**  
**OFFICE OF THE CHIEF ENGINEER**  
**LSGD (LPS&EW)**  
**THIRUVANANTHAPURAM**